

Draft Minnesota Rules, chapter 4725

SUBMERGED CLOSED LOOP HEAT EXCHANGERS

This is a DRAFT document. None of the proposed language changes are adopted or reflect current rule. Proposed language revisions are marked from the previously posted rule draft document. Language additions are underlined. Existing language proposed for removal is stricken with a ~~strike-out~~. Changes are accepted between document versions.

1 4725.0100 DEFINITIONS.

2 Subpart. 47b. **Submerged closed loop heat exchanger.** “submerged closed loop heat
3 exchanger” has the meaning given in Minnesota Statutes, section 1031.005, subdivision 17a.

4 Subp. 47c. Submerged closed loop heat exchanger device. “Submerged closed loop heat
5 exchanger device” means a device installed in a water-supply well and used to transfer heat
6 from the heat transfer fluid to the groundwater.

7 Subp. 47d. Submerged closed loop heat exchanger piping. “Submerged closed loop heat
8 exchanger piping” means piping and fittings of a submerged closed loop heat exchanger used to
9 convey heat transfer fluid and include:

- 10 1. Piping and fittings buried below the ground surface from the building to the well;
- 11 2. Piping and fittings installed in the water-supply well; and
- 12 3. Fittings connected to the piping in items 1 and 2 to the pitless unit.

13 Subp. 47ee. **Submerged closed loop heat exchanger system.** “Submerged closed loop heat
14 exchanger system” means a submerged closed loop heat exchanger installed in one or more
15 water-supply wells connected to a single building.

Minnesota Department of Health
Well Management Section
625 Robert St. N.
PO Box 64975
St. Paul, MN 55164-0975
651-201-4600 or 800-393-9808
wellrules.mdh@state.mn.us
www.health.state.mn.us

05/28/2024

To obtain this information in a different format, call: 651-201-4600 or 800-393-9808.