

Draft Minnesota Rules, chapter 4725

SUBMERGED CLOSED LOOP HEAT EXCHANGERS

This is a DRAFT document. None of the proposed language changes are adopted or reflect current rule. Proposed language revisions are marked from the previously posted rule draft document. Language additions are underlined. Existing language proposed for removal is stricken with a ~~strike-out~~. Changes are accepted between document versions.

4725.#### [SUBMERGED CLOSED LOOP HEAT EXCHANGERS – INSTALLATION REQUIREMENTS].

- 1 Subpart 1. Installation. A submerged closed loop heat exchanger system must be installed
2 according to standards in this part.
- 3 A. A water-supply well used for a submerged closed loop heat exchanger must meet the
4 requirements of this chapter and Minnesota Statutes, chapter 103I.
- 5 B. A well contractor must install a submerged closed loop heat exchanger device and
6 submerged closed loop heat exchanger piping in a well.
- 7 C. A well contractor must notify the commissioner:
- 8 (1) at least 24 hours prior to the initial installation of the submerged closed loop
9 heat exchanger system;
- 10 (2) by telephone, facsimile, email, or in person; and
- 11 (3) between 8:00 a.m. and 4:30 p.m., Monday through Friday, excluding holidays.
- 12 D. Submerged closed loop heat exchanger system piping connections to a water-supply
13 well or a water-supply system must be protected with a backflow prevention device as
14 specified in Uniform Plumbing Code (UPC) sections 603.0 to 603.5.23.4, as incorporated
15 by Minnesota Rules, part 4714.0050.
- 16 E. A heat transfer fluid sampling port must be installed on the submerged closed loop heat
17 exchanger system.
- 18 F. Submerged closed loop heat exchanger piping from the well to the building must be
19 marked by:
- 20 (1) tracer wire; or
- 21 (2) marking tape detectable from the ground surface.
- 22 Subp. 2. Submerged closed loop heat exchanger device.
- 23 A. Piping and tubing materials in the portions of the submerged closed loop heat
24 exchanger device containing heat transfer fluid must be:

- 25 (1) stainless steel meeting:
- 26 (a) ASTM Standard A240;
- 27 (b) ASTM Standard A249;
- 28 (c) ASTM Standard A269;
- 29 (d) ASTM Standard A312; or
- 30 (e) ASTM Standard A778; or
- 31 (2) copper or copper alloy meeting:
- 32 (a) ASTM Standard B42;
- 33 (b) ASTM Standard B43;
- 34 (c) ASTM Standard B302;
- 35 (d) ASTM Standard B75;
- 36 (e) ASTM Standard B88;
- 37 (f) ASTM Standard B135; or
- 38 (g) ASTM Standard B251;
- 39 B. Joints and connections in the portions of the submerged closed loop heat exchanger
- 40 device containing heat transfer fluid must be welded or soldered.
- 41 C. The submerged closed loop heat exchanger device must have a minimum pressure
- 42 rating of 160 psi or 1.5 times the maximum observed pressure for the heat exchanger in
- 43 the well;
- 44 **Subp. 3. Submerged closed loop heat exchanger piping.**
- 45 A. Submerged closed loop heat exchanger piping and fitting materials must be:
- 46 (1) provided in the Mechanical code sections 1210.4 and 1210.5, as incorporated by
- 47 Minnesota Rules, part 1346.0050; or
- 48 (2) stainless steel material meeting:
- 49 (a) ASTM Standard A269;
- 50 (b) ASTM Standard A312; or
- 51 (c) ASTM Standard A778.
- 52 B. Joints and connections must meet:
- 53 (1) requirements of Mechanical Code section 1210.6; or
- 54 (2) for stainless steel pipe, joints and connections must be watertight threaded or
- 55 welded joints that meet the following:
- 56 (a) threaded joints and connections must have recessed couplings, reamed
- 57 and drifted couplings, or other couplings that match the design, taper,

- 58 and thread type of the pipe. Thread must not be exposed on the pipe
59 when the pipe is joined.
- 60 (b) for welded joints and connections the pipe ends must be beveled, except
61 where an approved welding coupling is used. The weld must extend the
62 full circumference of the pipe and must completely fill the bevel.
- 63 (c) welding couplings must be made of material equivalent to the pipe. The
64 upper and lower welds must extend the full circumference of the pipe,
65 and completely fill the gap between the coupling and pipe. Welding the
66 pipe to the inside of the coupling is prohibited.
- 67 C. Submerged closed loop heat exchanger piping and fittings between the well and the
68 building must have a minimum pressure rating of:
- 69 (1) 100 psi; or
- 70 (2) 1.5 times the maximum operating pressure of the system.
- 71 D. Submerged closed loop heat exchanger piping and fittings in the well must have a
72 minimum pressure rating of:
- 73 (1) 160 psi; or
- 74 (2) 1.5 times the maximum observed pressure for that portion of the system in the
75 well;

Minnesota Department of Health
Well Management Section
625 Robert St. N.
PO Box 64975
St. Paul, MN 55164-0975
651-201-4600 or 800-393-9808
wellrules.mdh@state.mn.us
www.health.state.mn.us

05/28/2024

To obtain this information in a different format, call: 651-201-4600 or 800-393-9808.